

**TOWN OF COLLIERVILLE**

**CODE ENFORCEMENT DIVISION  
DEPARTMENT OF DEVELOPMENT**



**Smoke Alarm & Carbon Monoxide Alarm Requirements**

**Smoke alarms** shall be located outside each sleeping room in the immediate vicinity and inside each sleeping room and at each additional story or habitable attic.

**Carbon Monoxide alarms** shall be located outside each sleeping room in the immediate vicinity in dwelling units within which fuel-fired appliances are installed and in dwelling units that have attached garages.

**Meter replacement**, *gas or electrical*, and **Window replacement** shall permit the use of battery operated alarms.

**New construction, Addition, Alteration or Repair** shall require smoke alarms to be hard-wired with interconnection, *or other UL approved method*.

**Exceptions:**

1. Work involving the addition of a porch, deck or accessory structure is exempt from these requirements.
2. Repair of plumbing or mechanical systems are exempt from these requirements.
3. Interconnection of smoke alarms in existing areas shall not be required where alterations or repairs do not result in removal of interior wall or ceiling finishes exposing the structure, unless there is an attic, crawl space or basement available which could provide access for interconnection without the removal of interior finishes.

Note: A combination type, *smoke / carbon monoxide alarm*, shall be permitted at any location.