



NOTES:

1. CURB IS TO BE REMOVED AND REPLACED A MINIMUM OF 12" EACH SIDE OF DRAIN OPENING.
2. WHEN AN OPENING GREATER THAN A SINGLE 4" DIAMETER PIPE IS REQUIRED, A SIDEWALK DRAIN SHALL BE USED.
3. CONCRETE SHALL BE 4,000 PSI LIMESTONE
4. DRAIN PIPE SHALL BE SCHEDULE 80 OR SCHEDULE 40 PVC WITHIN R.O.W.
5. REPLACE FULL SIDEWALK PANEL

REVISION		
ITEM NO.	DESCRIPTION OF CHANGE	APPROVAL DATE
1	CHANGED PIPE TO SCH. 80 OR SCH. 40	1

**TOWN OF COLLIERVILLE
TYPICAL CURB CUT
FOR DRAIN PIPE**

SCALE: NONE

TOC-227