



SECTION A-A

NOTES

1. CASING INSULATORS SHALL BE MADE WITH SPECIAL RUNNER HEIGHTS SO AS NOT TO INTERFERE WITH PIPE JOINTS.
2. ALL CARRIER PIPES MUST HAVE FIELD LOCK GASKETS.
3. INSULATOR SPACING SHALL BE AS REQUIRED BY THE MANUFACTURER, HOWEVER, NO LESS THAN FOUR (4) CASING INSULATORS SHALL BE INSTALLED PER LENGTH OF PIPE.
4. CASING LENGTH SHALL EXTEND A MINIMUM OF 7 FEET BEYOND THE EDGE OF PAVEMENT OR CURBING.

REVISION		
ITEM NO.	DESCRIPTION OF CHANGE	APPROVAL DATE

**TOWN OF COLLIERVILLE
JACK AND BORE**

TOC-305