



- A. MAXIMUM DEPTH OF LIQUID, TYPICALLY A MINIMUM OF 42"
- B. INLET INVERT TO BE ABOVE MAXIMUM DEPTH
- C. BAFFLE WALL FLOW-THROUGH SLOT TO BE APPROXIMATELY 6" AND IN LOWER THIRD OF BAFFLE WALL (APPROXIMATELY 12" ABOVE THE INTERIOR FLOOR)
- D. ACCESS PORTS TO BE TRAFFIC RATED SEWER MANHOLE LID AND RIM ASSEMBLIES PER COLLIERVILLE STANDARD DETAIL TOC-303
- E. LOWER END OF OUTLET TEE TO BE GREATER THAN 2/3 A
- F. LOWER END OF INLET TEE TO BE A MINIMUM OF 12" BELOW MAXIMUM DEPTH OF LIQUID
- G. TOP OF SANITARY TEE AND BAFFLE WALL NOT TO EXCEED 6" BELOW THE INTERIOR ROOF
- H. SPECIFICATIONS TO BE SUBMITTED TO THE TOWN OF COLLIERVILLE PRIOR TO CONSTRUCTION

REVISION		
ITEM NO.	DESCRIPTION OF CHANGE	APPROVAL DATE

TOWN OF COLLIERVILLE

IN-GROUND GREASE
INTERCEPTOR DETAIL

TOC-311