



NOTES:

1. TO BE USED ON EXISTING MANHOLES.
2. A MAXIMUM OF 30" FROM FLOWLINE OF INFLUENT PIPE TO FLOWLINE OF MANHOLE BEFORE DROP CONSTRUCTION IS REQUIRED.
3. 4'-0" MAXIMUM SPACING BETWEEN STRAPS.
4. A MINIMUM OF THREE STRAPS ARE REQUIRED.
5. INSURE THAT MANHOLE STEPS AND DROP CONSTRUCTION LOCATIONS DO NOT INTERFERE.
6. A FOUR FOOT DIAMETER MANHOLE SHALL BE USED WHEN INSIDE PIPE IS 8" OR LESS. IF PIPE IS LARGER THAN 8", MANHOLE DIAMETER SHALL BE INCREASED ACCORDINGLY.
7. SDR 26 PVC PIPE SHALL BE USED ON ALL NEW CONSTRUCTION, WHEN DROPS ARE CONSTRUCTED WITHIN EXISTING MANHOLE.
8. OPENING IN MANHOLE TO BE GROUTED WITH HIGH STRENGTH, QUICK SETTING, NON-SHRINKING CEMENT GROUT.
9. CONCRETE MAY NEED TO BE POURED INSIDE MANHOLE IN ORDER TO PROVIDE A SMOOTH TRANSITION BETWEEN THE FLOWLINE OF THE INFLUENT PIPE AND THE FLOWLINE OF THE EFFLUENT PIPE.

REVISION		
ITEM NO.	DESCRIPTION OF CHANGE	APPROVAL DATE

**TOWN OF COLLIERVILLE
SANITARY MANHOLE-INSIDE
DROP CONSTRUCTION**

SCALE: NONE

TOC-315