



\* DISTANCES MAY VARY DEPENDENT UPON PROJECT

**NOTES:**

1. PUBLIC FIRE HYDRANTS TO BE SILVER IN COLOR
2. PRIVATE FIRE HYDRANTS TO BE RED IN COLOR.
3. CONCRETE PAD AROUND VALVE BOX TO BE 1" BELOW FINISHED GRADE.

REVISION		
ITEM NO.	DESCRIPTION OF CHANGE	APPROVAL DATE

**TOWN OF COLLIERVILLE  
FIRE HYDRANT ASSEMBLY**

SCALE: NONE

**TOC-401**