



SECTION A-A

**NOTES**

1. CASING INSULATORS SHALL BE MADE WITH SPECIAL RUNNER HEIGHTS SO AS NOT TO INTERFERE WITH PIPE JOINTS.
2. ALL CARRIER PIPES MUST HAVE RESTRAINED JOINTS.
3. INSULATOR SPACING SHALL BE AS REQUIRED BY THE MANUFACTURER, HOWEVER, NO LESS THAN FOUR (4) CASING INSULATORS SHALL BE INSTALLED PER 20 FEET OF PIPE.
4. CASING LENGTH SHALL EXTEND A MINIMUM OF 7 FEET BEYOND THE EDGE OF PAVEMENT OR CURBING.
5. SEE PLANS FOR CASING SIZE.

REVISION		
ITEM NO.	DESCRIPTION OF CHANGE	APPROVAL DATE

**TOWN OF COLLIERVILLE  
JACK AND BORE**

**TOC-404**