



NOTES:

1. EXPANSION JOINTS SHALL BE LOCATED AT ENDS OF RADIUS.
2. EXPANSION JOINTS SHALL BE INSTALLED AT 30 FT, MAXIMUM
3. EXPANSION JOINTS SHALL BE LOCATED A MAXIMUM OF 10 FT FROM INLET STRUCTURE.
4. PRE-CUT EXPANSION JOINT MATERIAL SHALL BE USED IN ALL EXPANSION JOINTS.
5. DUMMY JOINTS SHALL BE INSTALLED AT 10 FT INTERVALS, MAXIMUM.
6. CONCRETE TO BE 4000 PSI.

REVISION		
ITEM NO.	DESCRIPTION OF CHANGE	APPROVAL DATE

**TOWN OF COLLIERVILLE
6-18 MEDIAN CURB**

TOC-504