



NOT TO SCALE

NOTES:

1. EXPANSION JOINTS SHALL BE LOCATED AT ENDS OF RADIUS.
2. EXPANSION JOINTS SHALL BE INSTALLED AT 30 FT, MAXIMUM
3. EXPANSION JOINTS SHALL BE LOCATED A MAXIMUM OF 10 FT FROM INLET STRUCTURE.
4. PRE-CUT EXPANSION JOINT MATERIAL SHALL BE USED IN ALL EXPANSION JOINTS.
5. CONCRETE SHALL BE 4000 PSI

REVISION		
ITEM NO.	DESCRIPTION OF CHANGE	APPROVAL DATE

**TOWN OF COLLIERVILLE
6-18 VERTICAL CURB**

TOC-506