



NOTES:

1. DEPTH OF DEEP JOINT SHALL BE A MINIMUM OF 1/4 SLAB THICKNESS. FINISH WIDTH AT THE TOP SHALL BE A MAXIMUM OF 1/2 INCH.
2. TYPICAL SPACING FOR SCORE MARKS SHALL BE 5 FEET.
3. DEPTH OF CURB & GUTTER DEEP JOINT SHALL BE A MINIMUM OF 1/4 SIDEWALK SLAB THICKNESS OR 1 INCH, WHICHEVER IS GREATER. FINISH WIDTH AT THE TOP SHALL BE A MAXIMUM OF 1/2 INCH.
4. A CONSTRUCTION JOINT SHALL BE PLACED EVERY 30 FEET FOR BOTH SIDEWALK AND CURB & GUTTER.

REVISION		
ITEM NO.	DESCRIPTION OF CHANGE	APPROVAL DATE

TOWN OF COLLIERVILLE
 SCORE MARK DETAIL
 FOR CURB AND SIDEWALK

TOC-516