



NOTES:

1. LONGITUDINAL SLOPE SHALL NOT EXCEED 5% UNLESS NOTED OTHERWISE.
2. 6" SOIL CEMENT (10% CEMENT BY VOLUME) MAY BE SUBSTITUTED FOR AGGREGATE BASE AND GEOTEXTILE FABRIC. ANY OTHER PAVEMENT STRUCTURE SHALL BE PRE-APPROVED BY TOWN ENGINEER PRIOR TO CONSTRUCTION.
3. ROOT BARRIER TO BE PLACED A MINIMUM OF TEN (10) FEET BEYOND EACH SIDE OF AN EXISTING OR PROPOSED TREE(S) WHERE THE MATURE DRIPLINE WILL COVER OR ENCROACH ONTO THE TRAIL'S EDGE.

REVISION		
ITEM NO.	DESCRIPTION OF CHANGE	APPROVAL DATE
1	ADDED ROOT BARRIER	10-28-2020
2	ADDED NOTE 3	11-29-2023

**TOWN OF COLLIERVILLE
ASPHALT GREENWAY TRAIL**

SCALE: NONE

TOC-105